

HOUSINGS FOR FILTRATION CARTRIDGES

TECHNICAL INFORMATION 2

SPARE PARTS FOR COMMISSIONING AND MAINTENANCE

All Everblue's filter cartridge housings are manufactured according to the strictest construction standards and using only the highest quality raw materials exclusively made in Europe.

For this reason, it is not necessary to purchase spare parts for commissioning and maintenance operations for the first two years.

However, the filter cartridges contained inside them must be regularly replaced.

A well-designed filter cartridge filtration system should plan the replacement of the filter elements once a month.

A filtration system with filter cartridges, used as a pretreatment of a reverse osmosis system, if it has an adequate prefiltration, should expect the replacement of the filter elements twice a month.

The gaskets and o-rings, which guarantee the sealing of caps and lids affected by the opening and closing operations of the containers, must be replaced every time the cartridge replacement operations are carried out as prescribed by the seal and o-rings manufacturers.

Following the above, we recommend purchasing:

- N. 1 complete set of all o-rings and seals present in the purchased product
- N. 12 sets of gaskets and o-rings affected by the opening and closing of the containers for filtration systems
- N. 6 sets of gaskets and o-rings affected by the opening and closing of the containers for filtration systems installed as pre-treatment of the reverse osmosis systems.

